

Materialprüfungsamt Nordrhein-Westfalen - 44285 Dortmund

dormakaba Deutschland GmbH
DORMA Platz 1
58256 Ennepetal
Germany

Ihr Zeichen: PS
Ihre Nachricht vom : 05.09.2016
Unser Zeichen: mei
Durchwahl: 493
Direktfax: +49 (0)231 4502 586
E-Mail: meinks@mpanrw.de
Datum: 29.09.2016

Extension of validity of a test certificate.

Dear Ladies and Gentlemen,

Concerning the results of the initial type test carried out with the controlled door closing device DORMA BTS 80 F with sliding rail you applied for the extension of validity of test certificate no. 120000098.50-02.

The tests have been carried out on the base of the EN 1154:1996/A1:2002/AC:2006 (see test report no. 120000098.50-01).

You have also assured that the door closer was not modified since the initial type test.

Therefore the validity of the test certificate no. 120000098.50-02 is extended up to September 1st, 2021.

Best regards
By order



Th. Meinks
Technischer Amtsinspektor

Test Certificate No. 120000098.50-02

Contracting Party

DORMA GmbH & Co. KG
 Breckerfelder Str. 42-48
 D-58256 Ennepetal

Assignment

Testing of controlled door closing devices (door closer) in accordance with DIN EN 1154: 2003-04 (Ref. No. EN 1154: 1996 D +A1:2002). The tests are to be including the additional requirements according to annex A of DIN EN 1154.

Description of Samples

Floor spring door closer with adjustable latch, fix backcheck and sliding rail in accordance with illustration C.1.1 of DIN EN 1154 „**DORMA BTS 80F EN 4, EN 5, EN 6**“.

Description of the Test and Test Results

See Test Report No. 120000098.50-01.

Door leaf fixing corresponding with appendix 1.

Evaluation of the Test Results

The door closer „**DORMA BTS 80F EN 4, EN 5, EN 6**“ with a sliding rail arm mounted as shown on appendix 1 fulfils the requirements of the DIN EN 1154.

It is classified as follows in accordance with sec. 4 of DIN EN 1154:

Bezeichnung	Klassifizierungsschlüssel					
Dorma BTS 80F EN 4 with sliding rail	3*)	8	4	1	1	0
Dorma BTS 80F EN 5 with sliding rail	3*)	8	5	1	1	0
Dorma BTS 80F EN 6 with sliding rail	3*)	8	5	1	1	0

Dortmund, August, 10th 2006




Thorsten Meinks
 Technischer Amtsinspektor

This is the English version of „Prüfzeugnis Nr. 120000098.50-02“. The validity of this certificate expires on September 1st, 2011. This is a copy. In case of any misunderstandings the signed German version is valid only. The results of the tests are exclusively in relation to the test piece indicated above. Test certificates may without the consent of the MPA NRW only be published or reproduced in accordance with their unaltered form and content. The abbreviated reproduction of a test certificate is only permissible with the consent of the MPA NRW. This test certificate comprises 1 page and 1 appendix.

