



CERTIFICATE OF APPROVAL No CF 268

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

DORMA UK LIMITED

Wilbury Way, Hitchin, Hertfordshire SG4 0AB Tel: 01462 477600 Fax: 01462 477601

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT TS71, TS72V & TS72VBC Overhead Door Closers **TECHNICAL SCHEDULE**

TS 34 - The Contribution Of Controlled Door Closing Devices And Accessories To Fire Resisting Doorsets

Signed and sealed for and on behalf of Exova (UK) Limited trading as Warrington Certification

Paul Duggan
Certification Manager



Issued: 11th December 2001 Reissued: 16th March 2018 Valid to: 2nd February 2022

Page 1 of 6







TS71, TS72V & TS72VBC OVERHEAD DOOR CLOSERS

1. The Dorma UK Limited TS71, TS72V and TS72VBC are a range of adjustable power surface mounted overhead door closers. This approval relates to the following overhead mounted door closing devices and configurations:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
TS71	✓	✓	✓	×	*	*	×
TS72V	✓	✓	✓	×	×	×	×
TS72VBC	✓	✓	✓	×	×	×	×

Key: ✓ - approved **x** - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

2. This approval relates to their use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).

Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, <u>fully-insulated</u> for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM)

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in <u>fully-insulated</u> steel frames having a fire resistance up to 120 minutes (Code ITM)

3. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), the Technical Handbooks (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.

Page 2 of 6 Signed AJ/002

Pollegg-





TS71, TS72V & TS72VBC OVERHEAD DOOR CLOSERS

- 4. The closers are approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1
 - ii) An appraisal against TS34
 - iii) Inspection of quality management system
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
- 5. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
- 6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
- 7. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
- 8. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Page 3 of 6 Signed AJ/002

Pal lyg-





TS71, TS72V & TS72VBC OVERHEAD DOOR CLOSERS

9. The following tables show acceptable doorsets types and fire resistance periods:

	Approved Door Type					
Class	ММ	IMM	ITT	ITM	ITC	
FD20	√ *	√*	✓	√*	✓	
FD30	√ *	√*	✓	√*	✓	
FD60	√ *	√*	✓	√*	✓	
FD120	√ *	√*	✓	√*	✓	
FD240	√ *	√*	×	×	×	
E 20	×	×	✓	√*	✓	
EI 20	√ *	√*	✓	√*	✓	
E 30	×	×	✓	√*	✓	
EI 30	√ *	√*	✓	√ *	✓	
E 60	×	×	✓	√*	✓	
EI 60	√ *	√*	✓	√ *	✓	
E 90	×	×	✓	√*	✓	
EI 90	√ *	√*	✓	√ *	✓	
E 120	×	×	✓	√ *	✓	
EI 120	√ *	√*	✓	√ *	✓	
E 240	×	×	×	×	×	
EI 240	√ *	√*	×	×	×	

Kev.

- approved

Not approved

Fully-insulated steel-based doors and frames only

Page 4 of 6 Signed AJ/002

Pal ligg-





TS71, TS72V & TS72VBC OVERHEAD DOOR CLOSERS

10. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area.
- The closer may not be fitted to timber doorsets without intumescent protection.
- Closers are only approved for use with steel-based doors and frames that are fullyinsulated for the required classification period.
- · Mechanical Hold open option is not approved

Classification code

The approval provides the following classifications:

Dorma TS71, TS72V and TS72VBC when mounted in projecting arm (Figure 1) and transom mount (Figure 61)

4	8	4 3	1	1	2

Dorma TS71, TS72V and TS72VBC when mounted in parallel arm (Figure 6).

4 8	3	1	1	2
-----	---	---	---	---

Page 5 of 6 Signed AJ/002

Pal legg-





TS71, TS72V & TS72VBC OVERHEAD DOOR CLOSERS

Further Information

Further information regarding the details contained in this data sheet may be obtained from Dorma UK Limited (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 6 of 6 Signed AJ/002

Pal lygg-